



MOBILE HOMES EQUIPPED WITH POWER SUPPLY CORD AND PLUG RATED 40 AMPS OR 50 AMPS SHALL BE CONNECTED TO OUTSIDE SERVICE EQUIPMENT THROUGH A COMPATIBLE FEMALE RECEPTACLE AND SHALL BE PROTECTED BY A CIRCUIT BREAKER OR FUSE OF EQUAL RATING.

MOBILE HOME PARKS AND GROUPS OF TRAILERS WILL BE ENGINEERED ON AN INDIVIDUAL BASIS BY COOP PER NATIONAL ELECTRIC CODE.

			DATE: 9-21-90	JOE WHEELER ELECTRIC MEMBERSHIP CORP. HARTSELLE, ALABAMA	SCALE: SPEC NO. MH-12 PAGE 2
			DRAWN BY: C.R.		
1	UPDATED PER NESC	11/14/13	APP'D BY: S.K.C.	McWHORTER & FRANKLIN ENGINEERS	NASHVILLE, TENNESSEE
NO.	REVISION	DATE			